

MTI LADY READING HOSPITAL, PESHAWAR**TRANSFORMER REPAIR & MAINTENANCE SPECIFICATIONS**

S.No	Specifications	Rate
1000 KVA Transformer		
1	Replacement of HT coil	
2	Repair of HT coil	
3	Repair of LT coil	
4	Replacement of HT bush	
5	Replacement of LT bush	
6	Body Repair	
800 KVA Transformer		
1	Replacement of HT coil	
2	Repair of HT coil	
3	Repair of LT coil	
4	Replacement of HT bush	
5	Replacement of LT bush	
6	Body Repair	
730 KVA Transformer		
1	Replacement of HT coil	
2	Repair of HT coil	
3	Repair of LT coil	
4	Replacement of HT bush	
5	Replacement of LT bush	
6	Body Repair	
630 KVA Transformer		
1	Replacement of HT coil	
2	Repair of HT coil	
3	Repair of LT coil	
4	Replacement of HT bush	
5	Replacement of LT bush	
6	Body Repair	
500 KVA Transformer		
1	Replacement of HT coil	
2	Repair of HT coil	
3	Repair of LT coil	
4	Replacement of HT bush	
5	Replacement of LT bush	
6	Body Repair	
400 KVA Transformer		
1	Replacement of HT coil	

2	Repair of HT coil	
3	Repair of LT coil	
4	Replacement of HT bush	
5	Replacement of LT bush	
6	Body Repair	
200 KVA Transformer		
1	Replacement of HT coil	
2	Repair of HT coil	
3	Repair of LT coil	
4	Replacement of HT bush	
5	Replacement of LT bush	
6	Body Repair	
100 KVA Transformer		
1	Replacement of HT coil	
2	Repair of HT coil	
3	Repair of LT coil	
4	Replacement of HT bush	
5	Replacement of LT bush	
6	Body Repair	
50 KVA Transformer		
1	Replacement of HT coil	
2	Repair of HT coil	
3	Repair of LT coil	
4	Replacement of HT bush	
5	Replacement of LT bush	
6	Body Repair	
Total (Rs)		

Conditions for Transformer Repair Contract:

- 1 The workshop must provide us backup transformer free of cost for Emergency
- 2 Electricity Supply till the repair of faulty Transformer.
- 3 Crain and Transportation will provide by workshop free of cost.
- 4 The Replace parts must be returned to Equipment store Lady Reading Hospital.
- 5 The Acceptance of the Repair work will be subject to Inspection by the inspection Committee/Electrical Engineer LRH.
- 6 If the work /parts is found below standard or does not confirm to our
- 7 Warranty /Guarantee of the replaced parts will be 05months.
- 8 Before taking transformer for repair, the defective transformer should b
- 9 be inspected in the presence of Electrical Engineer of this hospital.
- 10 Self made H.T coil will not be accepted only original H.T coil made by company for the concerned transformer will be accepted.

